
# **TP24/7**

MITL SURGE TECHNOLOGIES A part of COOPER Crouse-Hinds

Safeguards 4 wire process transmitters against induced surges and transients from field cabling

- Specifically designed for Multivariable Transmitters and Level Transmitters
- Four wires protected, one pair at 12V to 24V and one pair at 7V (e.g. RS485)
- Easy and direct mounting simply screws into spare conduit entry
- Intrinsically safe and flameproof to CENELEC standards
- FM for US and Canada and ATEX approved



**The TP24/7 surge protection device** is a unique unit providing a level of protection for field-mounted transmitters that is far in excess of the optional transient protection facilities available from the transmitter manufacturers - without involving any additional wiring, conduit modifications or other expensive extras.

The TP24/7 protection network consists of high-power, solid-state electronics and a gas-filled discharge tube capable of diverting 10kA impulses. The whole unit is encased in an ANSI 316 stainless steel housing, threaded for the common conduit entries used on process transmitters. Versions are available for 1/2" NPT, 20mm ISO, and G1/2" (BSP 1/2 inch) threaded entries.

**Installation is very simple** and can easily be carried out retrospectively to existing installations. The TP24/7 is screwed into any unused conduit entry on the transmit-

ter case and flying leads are connected to the terminal block (+ve, -ve), RS485 terminals and the internal earth stud. They operate without in any way affecting normal operation - passing ac or dc signals without attenuation while diverting surge currents safely to earth and clamping output voltages to specific levels.

The all important earthing connection is made to the local casing of the transmitter with no separate earth connection or ground stake at the transmitter being needed. In operation, the TP24/7 makes sure that the transmitter electronics are never exposed to damaging transients between lines or between lines and casing/ earth. Any surge current appearing as a series-mode or common-mode transient is converted into a common-mode voltage - whereupon the transmitter electronics are temporarily raised to some higher voltage level before 'floating' down automatically (and without damage) to resume normal operation.

For hazardous-area use, approvals for both intrinsically safe and flameproof (explosionproof) operation are available, in all gas groups and apparatus temperature classification up to T4. Where transmitters are used in circuits suitable for Div 2/Zone 2 installations, the TP24/7 can be added without adversely affecting the level of safety.



Data & Signal Protection

# **Specification**

All figures typical at 77°F (25°C) unless otherwise stated

Maximum surge c	urrent
10kA peak cur	rrent (8/20µs waveform)
Leakage current	
	A at maximum working
voltage	
Working voltage	
12V to 24V do	
	m RS485 communications
Bandwidth	
1MHz	
Resistance	internal internal internal
Ambient temperat	introduced into loop
-40°C to +60°	
-40°C to +85°	
Humidity	Catologej
	H (non-condensing)
Electrical connect	
4 flying leads	
, 0	(0.2 (1.0mm2, 18 AWG)
	50mm (minimum)
Casing	
ANSI 316 stai	nless steel hexagonal barstock,
male thread	5
Threads	
TP24/7-N	1/2" NPT
TP24/7-I	20mm ISO (M20 x 1.5)
TP24/7-G	G 1/2" (BSP 1/2 inch)
Weight	
175g (6.2 oz)	
Dimensions	
See figure 1	
EMC compliance	
	munity Standards EN50082,
	istrial environments
Electrical safety	
	Ceq=O, Leq=O; the unit can be connected
	r certification into any intrinsically safe
loop with open <1.2W.	i circuit voltage <60V and input power
	ne unit is apparatus-approved to flame
	ne unit is apparatus-approved to name

o flame proof (explosionproof) standards, and can be fitted into a similarly approved housing.

### **SIL** information

#### Failure rates according to IEC 61508

	$\lambda_{_{\rm SD}}$	$\lambda_{su}^{*}$	λ <sub>dd</sub>	λου
TP24/7	O FIT	43 FIT	11 FIT	6 FIT
The user of t	he TP serie	s can utiliz	e these fai	lure rates in a

probabilistic model of a safety instrumented function (SIF) to determine the suitability in part for safety instrumented system (SIS) usage in a particular safety integrity level. A full table of failure rates in presented in the EXIDA report (section 4.4) along with all assumptions.


\*The Residual Effect failures are included in the Safe Undetected failure category according to IEC 61508. Note that these failures alone will not affect system reliability or safety and should therefore not be included in spurious trip calculations.


Safe Failure Fraction needs to be calculated on (sub)system level.

A complete copy of the EXIDA report can be downloaded at www.mtlsurge.com.

Note: In accordance with our policy of continuous improvement, we reserve the right to change the product's specification without notice.

Model		TP24/7
Nominal voltage	Un	24V/7V
Rated voltage (MCOV)	Uc	34V/7V
Nominal current	In	n/a
Nominal discharge current (8/20µs)	i <sub>sn</sub>	ЗkА
Max discharge current (8/20µs)	I <sub>max</sub>	10kA
Lightning impulse current (10/350µs)	l <sub>imp</sub>	2.5kA
Residual voltage @ i <sub>sn</sub>	Up	43V/19V
Voltage protection level @ 1kV/µs	Up	<36V/<12V
Bandwidth	fG	1MHz
Capacitance	С	100pF
Series resistance	R	n/a
Operating Temperature Range		-40°C to +85°C
Category tested		A2, B2, C1, C2, C3, D1
Overstressed fault mode i <sub>n</sub> =3kA		12kA
Impulse durability (8/20µs)		10kA
Degree of protection		IP66
AC durability		1A <sub>rms</sub> , 5T
Service conditions		80kPa - 160kPa 5% - 95% RH





# **Approvals**

Country (Authority)	Standard No.	Certificate/File	Approved for	Product
EC (BASEEFA)	EN 50014:1997 +	BASEEFA04ATEX0251X Amendments 1 & 2 EN 50020:1994, EN 50284:1999	EEx ia IIC T6 (Tamb = -40 to 60°C) EEx ia IIC T5 (Tamb = -40 to 85°C) EEx ia IIC T4 (Tamb = -40 to 60°C)	TP24/7-N-NDI TP24/7-I-NDI TP24/7-G-NDI
EC (BASEEFA)	EN 50014:1997 +	BASEEFA04ATEX0053X Amendments 1 & 2 EN 50018:2000 + Amendment 1	EEx d IIC T6 (Tamb = -40 to 60°C) EEx d IIC T5 (Tamb = -40 to 80°C) EEx d IIC T4 (Tamb = -40 to 85°C)	TP24/7-N-NDI TP24/7-I-NDI TP24/7-G-NDI
Atex Directive 94/9/EC	BS EN 50021:1999	TML02ATEX0032X	Ex n    T6 (-40°C <tamb<+60°c) EEx n    T5 (-40°C<tamb<+85°c)< td=""><td>TP24/7-N TP24/7-I TP24/7-G</td></tamb<+85°c)<></tamb<+60°c) 	TP24/7-N TP24/7-I TP24/7-G
USA (FM)	Class Nos. 3600 (1998), 3610 (1999), 3611 (1999), 3615 (1989), 3810 incl. Supp 1 (1995-07 (1989-03), ANSI/NEMA 250 (1991), ISA-S12.0.01 (1999)	3022293	Intrinsically Safe: I, II, III/1/A-G, I/O/IIC Explosionproof: I/1/A-D Non incendive: I/2/A-D, I/2/IIC Dust ignition proof: II,III/1/EFG Special protection: II/2/FG	TP24/7-N-NDI TP24/7-I-NDI TP24/7-G-NDI
Canada (FM)	C22.2 No. 157 C22.2 No. 213 C22.2 No 142 C22.2 No. 94 C22.2 No. 30	3025374	Intrinsically Safe: I, II, II/1/A-G, I/O/IIC Explosionproof: I/1/A-D Nonincendive: I/2/A-D, I/2/IIC Dust ignition proof: II, III/1/EFG Special protection: II/2/F	TP24/7 All
Global	IEC 60079-0:2004 IEC 60079-11:2006 IEC 61241-0:2004 IEC 61241-1:2004	IECEX BAS 07.0045X	Ex ia IIC T4/T5/T6 Ex tD A20 IP6X T85°C/T100°C/ T135°C	TP24/7-X-NDI

Note: TP24/7 part numbers ending in NDI are approved for IS, non-incendive and explosion proof installations.

## To order specify -

	Certified process transmitter surge protection device - $1/2$ " NPT thread
TP24/7-I-NDI	Certified process transmitter surge protection device - 20mm ISO thread
TP24/7-G-NDI	Certified process transmitter surge protection device - G 1/2" (BSP 1/2")
TP24/7-N	Non-certified process transmitter surge protection device - 1.2" NPT thread
TP24/7-I	Non-certified process transmitter surge protection device - 20mm ISO thread
TP24/7-G	Non-certified process transmitter surge protection device - G 1/2" (BSP 1/2")